

DRINKING WATER SAMPLING REPORT

Elms Elementary School

780 Patterson Road
Jackson, New Jersey, 08527

Report Date

April 29, 2025

Partner Project No.

24-447445.1

Prepared for:

Jackson Township Board of Education
Jackson, New Jersey 08527



Building
Science



Environmental
Consulting



Construction &
Development



Energy &
Sustainability



April 29, 2025

Anthony Bruno
Jackson Township Board of Education
151 Don Connor Boulevard
Jackson, New Jersey 08527

Subject: Drinking Water Sampling Report
 Elms Elementary School
 780 Patterson Road
 Jackson, New Jersey 08527
 Partner Project No. 24-447445.1

Dear Anthony Bruno,

Partner Engineering and Science, Inc. (Partner) is pleased to provide the *Drinking Water Sampling* of the abovementioned address (the "Subject Property"). This sampling event was performed in general conformance with the scope and limitations as detailed in our fee proposal. This inspection included a site reconnaissance as well as sampling and analysis. An assessment was made, conclusions stated, and recommendations outlined, as required.

This survey included a site reconnaissance as well as sampling and analysis. An assessment was conducted, conclusions stated, and recommendations outlined, as necessary.

We appreciate the opportunity to provide industrial hygiene services to Jackson Township Board of Education. If you have any questions concerning this report, or if we can assist you in any other matter, please contact me at (908) 497-8904.

Sincerely,

Partner Engineering and Science, Inc.

Dan Bracey, CIH, CSP, CHMM
Technical Director
EHS Solutions

EXECUTIVE SUMMARY

Partner presents our report for this Drinking Water Sampling Report of Elms Elementary School located at 780 Patterson Road, Jackson, New Jersey on March 1, 2025. Samples were collected according to the "New Jersey Department of Education N.J.A.C. 6A:26" requirements for testing of lead in New Jersey Schools and the "USEPA 3Ts for Reducing Lead in Drinking Water in Schools" recommendations, as well as the Safe Drinking Water Act of 1974.

The first sample at each fixture was a "first draw" which was collected directly from the fixture without letting the water run or flush. The second sample was collected after letting the water run (flush) for thirty seconds. This sample evaluates the lead in water from the water purveyor and the pipes outside the building. The samples collected were analyzed by EUROFINs Built Environment Testing, located in Mt. Laurel, New Jersey for analysis of lead content using ASTM Method D3559-15D for lead in drinking water. The action level for lead has been set at 15 parts per billion (ppb). According to the USEPA, given present technology and resources, this level is the lowest level to which water systems can reasonably be required to control this contaminant should it be present in drinking water.

Sample analysis indicated that measured lead concentrations did not exceed the USEPA Action Level of 15 ppb for lead at Elms Elementary School. No further action is recommended at this time. If additional outlets are added, or changes to existing outlets occur, the Client must perform lead sampling for those outlets.

TABLE OF CONTENTS

1.0	INTRODUCTION	1
1.1	Subject Property Description.....	1
1.2	Purpose and Scope	1
2.0	METHODOLOGY	2
3.0	ANALYTICAL RESULTS / CONCLUSIONS AND RECOMMENDATIONS	3
3.1	Conclusions and Recommendations	3
4.0	LIMITING CONDITIONS.....	4
5.0	SIGNATURES OF PROFESSIONALS	5

The following Appendices are attached at the end of this report.

Appendices

- Appendix A:** Table 1 – Analytical Results Table
Appendix B: Laboratory Analysis and Chain-of-Custody
Appendix C: Sample Location Diagram

1.0 INTRODUCTION

1.1 Subject Property Description

Address:	780 Patterson Road in Jackson, NJ
Nature of Use:	School
Walk-Through Inspector:	Hunter Hostage
Walk-Through Date:	January 14, 2025
Sampling Conducted By:	Juan Jimenez & Gianna Sandull
Sampling Date :	March 1, 2025

1.2 Purpose and Scope

The purpose of this drinking water sampling event was to sample and analyze drinking water for a determination of lead content for comparison with the USEPA Action Level as defined by the National Primary Drinking Water Regulations (NPDWR - 40 CFR Chapter I, Part 141), in addition to the "New Jersey Department of Education N.J.A.C. 6A:26" requirements for testing of lead in New Jersey Schools and the "USEPA 3Ts for Reducing Lead in Drinking Water in Schools". The NPDW set a Maximum Contaminant Level Goal (MCLG) for each listed contaminant, which identifies a level of that contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety and are non-enforceable public health goals. The MCLG for lead has been set at zero ppb. Since lead contamination generally occurs from corrosion of onsite lead pipes, or lead-based solder on fittings and fixtures, it cannot be directly detected or removed by the municipal water system. Instead, the USEPA is requiring municipal water systems to control the corrosiveness of their water if the level of lead at the tap exceeds an Action Level.

The action level for lead has been set at 15 parts per billion (ppb). According to the NPDWR Lead and Copper Rule (LCR), given present technology and resources, this level is the lowest level to which water systems can reasonably be required to control this contaminant should it be present in drinking water.

2.0 METHODOLOGY

Select drinking water samples were collected according to the "New Jersey Department of Education N.J.A.C. 6A:26" requirements for testing of lead in New Jersey Schools and the "USEPA 3Ts for Reducing Lead in Drinking Water in Schools" recommendations, as well as the LCR Monitoring requirements for lead in tap water (40 CFR Part 141, Subpart I, § 141.86(b)).

The first sample at each fixture was a "first draw" which was collected directly from the fixture without letting the water run or flush. The second sample was collected after letting the water run (flush) for thirty seconds. This sample evaluates the lead in water from the water purveyor and the pipes outside the building. Ideally, the water had not been used for the past eight hours prior to sampling and not longer than 48 hours prior to sampling. Partner made a reasonable effort to determine whether the stagnation preconditions were able to be met prior to conducting sampling.

Sample bottles were provided by EUROFINs Built Environment Testing located in Mt. Laurel, New Jersey with an appropriate preservative for lead in drinking water sampling. After collection, sample bottles were labeled with a unique identifier and transferred under chain of custody conditions to EUROFINs Built Environment Testing located in Mt. Laurel, New Jersey for analysis by ASTM Method D3559-15D. The laboratory results and chain of custody are contained in **Appendix B**.

3.0 ANALYTICAL RESULTS / CONCLUSIONS AND RECOMMENDATIONS

During the course of this site visit, Partner collected water samples at 49 locations. Partner did not attempt to disassemble mechanical equipment, open plumbing pipe chases, or assess materials within wall voids.

Sample names and their respective locations were updated from the 2021 sampling event based on relevant known plumbing information as provided by Elms Elementary School and the site guide.

Partner attempted to collect samples from the following outlets; however, based upon the condition of the outlet and recommendations from the site guide, a sample could not be collected at the following locations:

- EES-WF-03
- EES-WF-09
- EES-WF-15
- EES-WF-54

A total of 98 drinking water samples were collected from Elms Elementary School on March 1, 2025. A total of 49 samples were analyzed. The analytical results for all samples collected are listed in **Table 1** in **Appendix A**. Sample locations are depicted on the diagram included in **Appendix C**.

3.1 Conclusions and Recommendations

Sample analysis indicated that measured lead concentrations did not exceed the USEPA Action Level of 15 ppb for lead at Elms Elementary School. No further action is recommended at this time. If additional outlets are added, or changes to existing outlets occur, the Client must perform lead sampling for those outlets.

4.0 LIMITING CONDITIONS

No warranties expressed or implied, are made by Partner or its subcontractor, EUROFINS Built Environment Testing, or their employees as to the use of any information, apparatus, product, or process disclosed in this report. Every reasonable effort has been made to assure correctness. This survey is limited by the scope discussed by the client. It was prepared for the sole use and benefit of the Client. Neither this report nor any of the information contained herein shall be used or relied upon for any purpose by any persons or entities other than the Client.

Property and climate conditions, as well as local, state, and federal regulations, can change significantly over time. Therefore, the recommendations and conclusions presented as a result of this study apply strictly to the environmental regulations and property conditions existing at the time the study was performed. Available information has been analyzed using currently accepted industry assessment techniques and it is believed that the inferences made are reasonably representative of the property. Partner and its subcontractor EUROFINS Built Environment Testing and their employees/representatives bear no responsibility for the actual condition of the structure or safety of this site pertaining to water quality contamination regardless of the actions taken by the inspection team or the client. Partner makes no warranty, expressed or implied, except that the services have been performed in accordance with generally accepted assessment practices applicable at the time and location of the study.

5.0 SIGNATURES OF PROFESSIONALS

Partner has performed lead-in-drinking water sampling on the property at 780 Patterson Road, Jackson, New Jersey in general conformance with the scope and limitations of the protocol and the limitations stated earlier in this report. Exceptions to or deletions from this protocol are discussed earlier in this report.

Prepared By:

Partner Engineering and Science, Inc.



Juan Jimenez
Industrial Hygienist

Reviewed by:



Daniel Bracey, CIH, CSP, CHMM
Technical Director

APPENDIX A: TABLE 1 – ANALYTICAL RESULTS TABLE

Table 1: Analytical Results		
Sample Name	Location	Results (ppb)
EES-S-01	Kitchen 305	<1.00
EES-S-02	Faculty Lounge	3.60
EES-WF-04	Across 302	<1.00
EES-BF-05	Across 302	<1.00
EES-WF-06	Classroom 101	2.20
EES-WF-07	Classroom 102	6.40
EES-WF-08	Classroom 104	1.00
EES-WF-10	Classroom 105	<1.00
EES-WF-11	Classroom 106	<1.00
EES-WF-12	Classroom 107	<1.00
EES-WF-13	Classroom 109	1.40
EES-WF-14	Classroom 110	2.20
EES-S-16	Nurse	1.80
EES-WF-17	Nurse	1.40
EES-WF-20	Classroom 127	4.60
EES-WF-21	Classroom 125	2.70
EES-WF-22	Classroom 122	2.50
EES-WF-23	Classroom 120	1.10
EES-WF-24	Classroom 123	1.90
EES-WF-25	Classroom 121	1.00
EES-WF-26	Classroom 118	1.50
EES-WF-27	Classroom 116	3.20
EES-WF-28	Classroom 119	1.20
EES-WF-29	Across From 100-WJ	<1.00
EES-WF-30	Across From 100-WJ	<1.00
EES-WF-31	Across S4	<1.00
EES-BF-32	Across S4	<1.00
EES-WF-33	CR 229	7.40
EES-WF-34	CR 227	<1.00
EES-WF-35	CR 222	<1.00

Table 1: Analytical Results		
Sample Name	Location	Results (ppb)
EES-WF-36	CR 220	<1.00
EES-WF-37	CR 225	1.10
EES-BF-38	CR 218	4.00
EES-BF-39	CR 223	1.30
EES-BF-40	CR 221	2.50
EES-BF-41	CR 216	1.00
EES-BF-42	CR 219	1.10
EES-BF-43	CR 214	<1.00
EES-BF-44	CR 203	<1.00
EES-WF-45	CR 202	2.50
EES-WF-46	CR 204	1.00
EES-WF-47	CR 205	1.70
EES-WF-48	CR 207	1.60
EES-WF-49	CR 206	1.80
EES-WF-50	CR 208	1.00
EES-WF-51	CR 209	<1.00
EES-WF-52	Across 200ES	<1.00
EES-BF-53	Across 200ES	<1.00
EES-S-55	Faculty Rm	<1.00

1 ppb = 1 ug/L

APPENDIX B: LABORATORY ANALYSIS AND CHAIN-OF-CUSTODY

CERTIFICATE OF ANALYSIS


Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712
Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826411 Client No.:EES-S-01	Location:Kitchen 305 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826412 Client No.:EES-S-01-F	Location:Kitchen 305 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826413 Client No.:EES-S-02	Location:Faculty Lounge * Sample acidified to pH <2.	Result(ppb):3.60
Lab No.:7826414 Client No.:EES-S-02-F	Location:Faculty Lounge * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826415 Client No.:EES-WF-04	Location:Across 302 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826416 Client No.:EES-WF-04-F	Location:Across 302 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826417 Client No.:EES-BF-05	Location:Across 302 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826418 Client No.:EES-BF-05-F	Location:Across 302 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826419 Client No.:EES-WF-06	Location:Classroom 101 * Sample acidified to pH <2.	Result(ppb):2.20
Lab No.:7826420 Client No.:EES-WF-06-F	Location:Classroom 101 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS


Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712
Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826421 Client No.:EES-WF-07	Location:Classroom 102 * Sample acidified to pH <2.	Result(ppb):6.40
Lab No.:7826422 Client No.:EES-WF-07-F	Location:Classroom 102 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826423 Client No.:EEG-WF-08	Location:Classroom 104 * Sample acidified to pH <2.	Result(ppb):1.00
Lab No.:7826424 Client No.:EEG-WF-08-F	Location:Classroom 104 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826425 Client No.:EEG-WF-10	Location:Classroom 105 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826426 Client No.:EEG-WF-10-F	Location:Classroom 105 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826427 Client No.:EEG-WF-11	Location:Classroom 106 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826428 Client No.:EEG-WF-11-F	Location:Classroom 106 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826429 Client No.:EEG-WF-12	Location:Classroom 107 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826430 Client No.:EEG-WF-12-F	Location:Classroom 107 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1


Client: PAR929

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826431 Client No.:EEG-WF-13	Location:Classroom 109 * Sample acidified to pH <2.	Result(ppb):1.40
Lab No.:7826432 Client No.:EEG-WF-13-F	Location:Classroom 109 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826433 Client No.:EEG-WF-14	Location:Classroom 110 * Sample acidified to pH <2.	Result(ppb):2.20
Lab No.:7826434 Client No.:EEG-WF-14-F	Location:Classroom 110 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826435 Client No.:EEG-S-16	Location:Nurse * Sample acidified to pH <2.	Result(ppb):1.80
Lab No.:7826436 Client No.:EEG-S-16-F	Location:Nurse * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826437 Client No.:EEG-WF-17	Location:Nurse * Sample acidified to pH <2.	Result(ppb):1.40
Lab No.:7826438 Client No.:EEG-WF-17-F	Location:Nurse * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826439 Client No.:EEG-WF-20	Location:Classroom 127 * Sample acidified to pH <2.	Result(ppb):4.60
Lab No.:7826440 Client No.:EEG-WF-20-F	Location:Classroom 127 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS


Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712
Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826441 Client No.:EEG-WF-21	Location:Classroom 125 * Sample acidified to pH <2.	Result(ppb):2.70
Lab No.:7826442 Client No.:EEG-WF-21-F	Location:Classroom 125 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826443 Client No.:EEG-WF-22	Location:Classroom 122 * Sample acidified to pH <2.	Result(ppb):2.50
Lab No.:7826444 Client No.:EEG-WF-22-F	Location:Classroom 122 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826445 Client No.:EEG-WF-23	Location:Classroom 120 * Sample acidified to pH <2.	Result(ppb):1.10
Lab No.:7826446 Client No.:EEG-WF-23-F	Location:Classroom 120 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826447 Client No.:EES-WF-24	Location:Classroom 123 * Sample acidified to pH <2.	Result(ppb):1.90
Lab No.:7826448 Client No.:EES-WF-24-F	Location:Classroom 123 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826449 Client No.:EES-WF-25	Location:Classroom 121 * Sample acidified to pH <2.	Result(ppb):1.00
Lab No.:7826450 Client No.:EES-WF-25-F	Location:Classroom 121 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712


Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826451 Client No.:EES-WF-26	Location:Classroom 118 * Sample acidified to pH <2.	Result(ppb):1.50
Lab No.:7826452 Client No.:EES-WF-26-F	Location:Classroom 118 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826453 Client No.:EES-WF-27	Location:Classroom 116 * Sample acidified to pH <2.	Result(ppb):3.20
Lab No.:7826454 Client No.:EES-WF-27-F	Location:Classroom 116 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826455 Client No.:EES-WF-28	Location:Classroom 119 * Sample acidified to pH <2.	Result(ppb):1.20
Lab No.:7826456 Client No.:EES-WF-28-F	Location:Classroom 119 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826457 Client No.:EES-WF-29	Location:Across From 100-WJ * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826458 Client No.:EES-WF-29-F	Location:Across From 100-WJ * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826459 Client No.:EES-WF-30	Location:Across From 100-WJ * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826460 Client No.:EES-WF-30-F	Location:Across From 100-WJ * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director



CERTIFICATE OF ANALYSIS


Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712
Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826461 Client No.:EES-WF-31	Location:Across S4 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826462 Client No.:EES-WF-31-F	Location:Across S4 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826463 Client No.:EES-BF-32	Location:Across S4 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826464 Client No.:EES-BF-32-F	Location:Across S4 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826465 Client No.:EES-WF-33	Location:CR 229 * Sample acidified to pH <2.	Result(ppb):7.40
Lab No.:7826466 Client No.:EES-WF-33-F	Location:CR 229 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826467 Client No.:EES-WF-34	Location:CR 227 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826468 Client No.:EES-WF-34-F	Location:CR 227 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826469 Client No.:EES-WF-35	Location:CR 222 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826470 Client No.:EES-WF-35-F	Location:CR 222 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712


Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826471 Client No.:EES-WF-36	Location:CR 220 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826472 Client No.:EES-WF-36-F	Location:CR 220 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826473 Client No.:EES-WF-37	Location:CR 225 * Sample acidified to pH <2.	Result(ppb):1.10
Lab No.:7826474 Client No.:EES-WF-37-F	Location:CR 225 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826475 Client No.:EES-BF-38	Location:CR 218 * Sample acidified to pH <2.	Result(ppb):4.00
Lab No.:7826476 Client No.:EES-BF-38-F	Location:CR 218 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826477 Client No.:EES-BF-39	Location:CR 223 * Sample acidified to pH <2.	Result(ppb):1.30
Lab No.:7826478 Client No.:EES-BF-39-F	Location:CR 223 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826479 Client No.:EES-BF-40	Location:CR 221 * Sample acidified to pH <2.	Result(ppb):2.50
Lab No.:7826480 Client No.:EES-BF-40-F	Location:CR 221 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1


Client: PAR929

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826481 Client No.:EES-BF-41	Location:CR 216 * Sample acidified to pH <2.	Result(ppb):1.00
Lab No.:7826482 Client No.:EES-BF-41-F	Location:CR 216 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826483 Client No.:EES-BF-42	Location:CR 219 * Sample acidified to pH <2.	Result(ppb):1.10
Lab No.:7826484 Client No.:EES-BF-42-F	Location:CR 219 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826485 Client No.:EES-BF-43	Location:CR 214 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826486 Client No.:EES-BF-43-F	Location:CR 214 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826487 Client No.:EES-BF-44	Location:CR 203 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826488 Client No.:EES-BF-44-F	Location:CR 203 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826489 Client No.:EES-WF-45	Location:CR 202 * Sample acidified to pH <2.	Result(ppb):2.50
Lab No.:7826490 Client No.:EES-WF-45-F	Location:CR 202 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director



CERTIFICATE OF ANALYSIS


Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712
Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826491 Client No.:EES-WF-46	Location:CR 204 * Sample acidified to pH <2.	Result(ppb):1.00
Lab No.:7826492 Client No.:EES-WF-46-F	Location:CR 204 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826493 Client No.:EES-WF-47	Location:CR 205 * Sample acidified to pH <2.	Result(ppb):1.70
Lab No.:7826494 Client No.:EES-WF-47-F	Location:CR 205 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826495 Client No.:EES-WF-48	Location:CR 207 * Sample acidified to pH <2.	Result(ppb):1.60
Lab No.:7826496 Client No.:EES-WF-48-F	Location:CR 207 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/14/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS


Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712
Client: PAR929


Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7826497 Client No.:EES-WF-49	Location:CR 206 * Sample acidified to pH <2.	Result(ppb):1.80
Lab No.:7826498 Client No.:EES-WF-49-F	Location:CR 206 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826499 Client No.:EES-WF-50	Location:CR 208 * Sample acidified to pH <2.	Result(ppb):1.00
Lab No.:7826500 Client No.:EES-WF-50-F	Location:CR 208 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826501 Client No.:EES-WF-51	Location:CR 209 * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826502 Client No.:EES-WF-51-F	Location:CR 209 * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826503 Client No.:EES-WF-52	Location:Across 200ES * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826504 Client No.:EES-WF-52-F	Location:Across 200ES * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed
Lab No.:7826505 Client No.:EES-BF-53	Location:Across 200ES * Sample acidified to pH <2.	Result(ppb):<1.00
Lab No.:7826506 Client No.:EES-BF-53-F	Location:Across 200ES * Sample acidified to pH <2.	Result(ppb):Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/17/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director



CERTIFICATE OF ANALYSIS

Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712

Client: PAR929

Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7826507
Client No.: EES-S-55

Location: Faculty Rm
* Sample acidified to pH <2.


Result(ppb): <1.00


Lab No.: 7826508
Client No.: EES-S-55-F

Location: Faculty Rm
* Sample acidified to pH <2.

Result(ppb): Sample Not Analyzed

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 3/4/2025
Date Analyzed: 03/17/2025
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712

Client: PAR929

Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

Appendix to Analytical Report:

Customer Contact:

Analysis: AAS-GF - ASTM D3559-15D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: ?wchampion@iatl.com

iATL Account Representative: House Account

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-15D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Partner Engineering and Science
929 Asbury Ave
Asbury Park NJ 07712

Client: PAR929

Report Date: 3/17/2025
Report No.: 710474 - Lead Water
Project: Jackson LIDW 2024; Elms Elementary
Project No.: 24-447445.1

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.


Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.


APPENDIX C: SAMPLE LOCATION DIAGRAM



Ⓐ FIRST FLOOR PLAN

ELMS ELEMENTARY SCHOOL

Elms Elementary School
780 Patterson Road
Jackson, NJ 08527



Ⓑ SECOND FLOOR PLAN